



中国船级社
CHINA CLASSIFICATION SOCIETY

证书编号/Certificate No.
HB24PTB00066_01

型式认可证书
CERTIFICATE OF TYPE APPROVAL

兹证明本证书所述制造厂具备按照下列标准的要求生产本证书所列产品的能力和条件。

This is to certify that the manufacturer stated in the certificate meets the requirements of the standards listed below and is available with the ability and conditions to produce the products described in the certificate.

制造厂/Manufacturer

BD SENSORS GmbH

地址/Address

BD Sensors-Str. 1 D-95199, Thierstein Deutschland

产品名称/Product

压力变送器
Pressure Transmitter

认可标准/Approval Standard

- 中国船级社《钢质海船入级规范》第7篇第2章
Chapter 2, Part Seven of China Classification Society Rules for Classification of Sea-going Steel Ships

用于/Intended for

船舶/Ships

产品明细/Product Description

压力变送器/Pressure Transmitter (M0001)

名称/Name	属性(值)/Value	单位/Unit
产品名称/Product Name	Pressure Transmitter	
型号/Type	DMK 457(Standard version), DX19-DMK 457(Ex version), DMP 457(Standard version), DX19-DMP 457(Ex version), DMK 458(Standard version), DX14A-DMK 458(Ex version), 17. 457G, 18. 457G, 26. 457G, 30. 457G	
输出信号/Output Signal	See additional page(s)	
测量范围/Measure Range	See additional page(s)	
额定电压/Rated Voltage	See additional page(s)	V
外壳防护等级/Degrees of Protection	See additional page(s)	

证书有效期至/This Certificate is valid until 2030年01月15日/Jan. 15,2030

发证机构/Issued by 中国船级社汉堡分公司
CHINA CLASSIFICATION SOCIETY Hamburg Branch

签发日期/Date 2025年01月16日
Jan. 16,2025

本证书根据中国船级社规范和相关规定签发。所有证书页为一个整体，必须同时使用。纸质证书每页均须由本社盖章方为有效，电子证书含数字签名方为有效，本证书复印件无效。任何单位和个人均不应摘录或节选本证书的部分内容。有关方对所持证书的真实性有疑问时，可以向本社检验机构咨询。本证书凡是未注明版本的规范，其（发证时）最新版本适用于本证书。
This Certificate is issued pursuant to the Rules of the Society and related regulation. All pages of the certificate are taken as a whole and are used simultaneously. No paper certificate page is valid without bearing the stamp of the Society, no electronic certificates is valid without the digital signature, and no copied form of the certificate is regarded as valid. Any part of the certificate is not to be extracted or abridged by any unit or individual in any form. Related parties who are doubted about the authenticity of the certificate may inquire of the Society or its offices. For Rules with no version indication, their latest version (at the time of issuance of the certificate) applies to the this certificate.



Form No: T01.

联系方式/Contact Us, 见本社官方网站/See official web site of the Society (<http://www.ccs.org.cn>)

UTN:P025-38272606

防爆标志/Explosion-Proof Marking	See additional page(s)	
------------------------------	------------------------	--

批准的图纸/Approved Drawings

图纸批准号/ Drawings Approval No. : HB16A00021

产品认可试验报告/ Approval Test Report

试验报告编号/ Test Report No. : EMV Services 09/8152-2-1
 试验报告日期/ Test Report Date : 2009-02-02
 试验单位/ Laboratory: EMV Services GmbH & Co. KG
 试验单位地址/ Test Address: Harburger Schlosstr.6-12, D-21079 Hamburg

试验报告编号/ Test Report No. : Paconsult 07-1590
 试验报告日期/ Test Report Date : 2007-10-26
 试验单位/ Laboratory: Paconsult GmbH
 试验单位地址/ Test Address: Ulmenau 6-10, D-22087 Hamburg

试验报告编号/ Test Report No. : Paconsult 07-1481
 试验报告日期/ Test Report Date : 2007-03-21
 试验单位/ Laboratory: Paconsult GmbH
 试验单位地址/ Test Address: Ulmenau 6-10, D-22087 Hamburg

试验报告编号/ Test Report No. : Carsynergies P05-0030
 试验报告日期/ Test Report Date : 2005-03-02
 试验单位/ Laboratory: Car Synergies GmbH
 试验单位地址/ Test Address: Dinnendahlstr. 9, D-44809, Bochum Germany

试验报告编号/ Test Report No. : 073011.173.21 V1.0
 试验报告日期/ Test Report Date : 2021-09-09
 试验单位/ Laboratory: MeßTechnikNord GmbH
 试验单位地址/ Test Address: Industriestraße 29 D-22880 Wedel - Germany

试验报告编号/ Test Report No. : EMV Services 10/1068-4
 试验报告日期/ Test Report Date : 2010-12-15
 试验单位/ Laboratory: EMV Services GmbH & Co. KG
 试验单位地址/ Test Address: Harburger Schlosstr.6-12, D-21079 Hamburg

试验报告编号/ Test Report No. : EMV Services 09/9036-1, 2-1, 2-2, 3-1, -4
 试验报告日期/ Test Report Date : 2009-09-01
 试验单位/ Laboratory: EMV Services GmbH & Co. KG
 试验单位地址/ Test Address: Harburger Schlosstr.6-12, D-21079 Hamburg

试验报告编号/ Test Report No. : BSFV 6873/09
 试验报告日期/ Test Report Date : 2010-04-16
 试验单位/ Laboratory: Institut fuer BFSV
 试验单位地址/ Test Address: Lohbruegger Kirchstr.65, D-21033 Hamburg, Germany

试验报告编号/ Test Report No. : BSFV 6196, 6817, 6873
 试验报告日期/ Test Report Date : 2010-04-16
 试验单位/ Laboratory: Institut fuer BFSV
 试验单位地址/ Test Address: Lohbruegger Kirchstr.65, D-21033 Hamburg, Germany

认可后的产品检验方式/ Method of Product Inspection after Approval

按规范只认可不进行产品检验的产品/The product approved only in term of the rules:
 认可后的产品由制造厂检验合格后签发合格证明, 并连同该产品的本社认可证书复印件一并交付用户, 制造厂对产品符合公约、法规、本社规范和本社认可的标准规定负责。

After approval, product inspection should be carried out by the Manufacturer. Upon satisfactory inspection, and the Quality Certificate issued by the Manufacturer should be provided to the purchaser together with the copy of the approval certificate issued by the Society. The manufacturer should take responsibility for the product being in compliance with the convention, statutory regulation, the Society rules and the standard accepted by the Society.

认可保持条件/ Maintenance Requirements of Approval

1. 型式认可后, 如果产品及其重要零部件的设计、所用材料或制造方法有所改变, 且影响到产品的主要特性、特征; 或产品的性能指标有所更改, 且超过认可的范围, 则有关图纸和文件应经检验机构审批。并在检验机构认为必要时, 经本社检验人员见证有关试验和进行检查, 其结果应能证实仍符合认可条件。

After type approval, if there are changes to the design, materials used or manufacturing method of the product and important components and such changes affect major characteristics and properties of the product, or property indexes of the product are changed and exceed the scope of approval, related drawings and documents are to be examined and approved by the concerned survey office. Where deemed necessary by the survey office, the surveyor to the Society will go to witness relevant tests and conduct inspection and the results should be able to demonstrate compliance with the approval conditions.

2. 工厂的质量管理体系应保持有效运行, 并且与认可时一致。如果质量管理体系发生改变, 应经原体系认证机构审核并报本社批准。

The quality management system of the factory shall be ensure effective operation, and shall be the same as the situation of approval. If there are any changes to the quality management system, auditing of the original certification organization for quality management system and the society's approval shall be obtained.

3. 认可证书有效期内, 如果出现可能导致本社取消认可的情况, 工厂应及时采取有效的纠正措施。

Within the validity of the approval certificate, if cases occur that may cause the Society to withdraw the approval, the manufacturer should take corrective actions in a prompt and effective manner.

4. 在认可证书有效期内, 本社检验人员可在未经事先通知的情况下对工厂的产品制造过程进行审核, 以验证产品的生产是否符合业经本社批准的图纸和文件。工厂应予以配合。

Within the validity of the approval certificate, the surveyor to the Society may pay unannounced audit to the manufacturing process of the product in order to confirm whether it is in compliance with the drawings and documents approved by the Society. The factory should provide an active cooperation and necessary for the surveyor.

5. 证书获得者应接受本社每年一次的定期审核, 定期审核日为认可证书期满之日对应的每一周年日, 检查工作应在周年日的前后三个月内进行。

Those who have obtained the certificate should be subject to periodical audit every year. The date of periodical audit shall be each anniversary date which corresponds to the date of expiry of the relevant certificate and the periodical audit shall be done within a time span of three months before and after the annual surveillance date.

备注/Remarks

本社已审核了产品厂无石棉声明, 但本社的审核不免除产品厂按照合同关系向订货方保证产品无石棉的责任。The declaration of asbestos-free submitted by manufacturer has been reviewed by the Society. However, liability of the manufacturer to guarantee the products are asbestos-free to purchaser under contract will not be exempted.

Place of Manufacture:

1. BD SENSORS GmbH; BD-Sensors-Str.1, D-95199 Thierstein Germany
2. BD SENSORS s.r.o. ; Hradistska 817, CZ-68708 Buchlovice, Czech republic

中国船级社汉堡分社
CCS Hamburg Branch

注: 本证书含有附页, 共3页

Note: The certificate is attached with additional 3 page(s)

Technical data and Range of application:

1、 Type DMK 457(Standard version), DX19-DMK457(Ex version) With ceramic sensor element

Nominal pressure range	0-0.4 up to 0-600 bar
Power supply	24V rated (10-32V DC) Ex version (12-28V DC)
Output signal	4-20mA, 2-wire
Electrical connection	Plug acc. to ISO 4400(standard), cable gland, cable outlet (cable with air tube), field housing
Mechanical connection	screw-in
Material housing	<p>DMK457: Standard: stainless steel 1.4404 (316L) Option: CuNi10Fe1Mn in combination with pressure port in CuNi10Fe1Mn Option field housing- stainless steel 1.4404(316L); with cable gland</p> <p>DMK457/DX19-DMK457: Standard: stainless steel 1.4404(316L) Option: CuNi10Fe1Mn in combination with pressure port in CuNi10Fe1Mn Option field housing- stainless steel 1.4404(316L); with cable gland</p>
Explosion protection	<p>DX19-DMK457: Non-metallic pressure connection : II 2G Ex ia IIB T4 Gb ; II 2D Ex ia IIIC T85 ° C Db Metallic pressure connection : II 1G Ex ia IIB T4 Ga ;II 1D Ex ia IIIC T135° C Da Standards for Ex-Proof: EN 60079-0:2018; EN IEC 60079-11:2012; (acc. To the Ex-proof certificate IBEU 10 ATEX1068 X issued by IBEU Institut fuer Sicherheitstechnik GmbH)</p>
Degree of protection	IP65(plug); IP67(cable gland and field housing); IP68(cable outlet)

—To be continued—

2、Type DMP 457(Standard version), DX19-DMP457(Ex version) With piezoresistive stainless steel sensor element

Nominal pressure range	0-0.1 up to 0-600bar
Power supply	24V rated(10-32V DC); Ex version (12-28V DC)
Output signal	4-20mA, 2-wire
Electrical connection	Plug acc. to ISO 4400(standard), cable gland, cable outlet(cable with air tube), field housing
Mechanical connection	screw-in
Material housing	<p>DMP457: Standard: stainless steel 1.4404 (316L) Option: CuNi10Fe1Mn in combination with pressure port in CuNi10Fe1Mn Option field housing- stainless steel 1.4404(316L); with cable gland</p> <p>DMP457/DX19-DMP457: Standard: stainless steel 1.4404(316L) Option: CuNi10Fe1Mn in combination with pressure port in CuNi10Fe1Mn Option field housing- stainless steel 1.4404(316L); with cable gland</p>
Explosion protection	<p>DX19-DMP457: Non-metallic pressure connection : II 2G Ex ia IIB T4 Gb ; II 2D Ex ia IIIC T85 ° C Db Metallic pressure connection : II 1G Ex ia IIB T4 Ga ;II 1D Ex ia IIIC T135°C Da Standards for Ex-Proof: EN IEC 60079-0:2018; EN 60079-11:2012; (acc. To the Ex-proof certificate IBEU 10 ATEX1068 X issued by IBEU Institut fuer Sicherheitstechnik GmbH)</p>
Degree of protection	IP65(plug), IP67(cable gland and field housing) IP68(cable outlet)

—To be continued—

3、Type DMK 458(Standard version) ,DX14A-DMK458(Ex version) Hydrostatic transmitter with ceramic-capacitive sensor element

Nominal pressure range	0-0.04 up to 0-20bar
Power supply	24V rated(10-32V DC) Ex version (12-28V DC)
Output signal	4-20mA, 2-wire
Electrical connection	Plug, cable gland, cable outlet, field housing
Mechanical connection	screw-in
Material housing	Standard: stainless steel 1.4404(316L) Option: material pressure port for threaded connections: copper-nickel alloy
Explosion protection	II 1G Ex ia IIB T4 Ga Standards for Ex-Proof: EN 60079-0:2012+A11: 2013; EN 60079-11:2012. (acc.To the Ex-proof certificate IExU 07 ATEX 1180 X issued by IExU Institut fuer Sicherheitstechnik GmbH)
Degree of protection	IP65(plug), IP67(cable gland and field housing) IP68(cable outlet)

4、Type 17.457G, 18.457G, 26.457G, 30.457G Pressure transmitter

Nominal pressure range	17.457G(stainless steel sensor, weld) 0-6 up to 0-600bar 18.457G(piezoresistive stainless steel sensor) 0-0.1 up to 0-6bar 26.457G(ceramic sensor) 0-1 up to 0-160bar 30.457G(ceramic sensor) 0-1.6 up to 0-250bar
Power supply	24V DC rated (8-32V DC)
Output signal	4-20mA, 2-wire
Electrical connection & (Degree of protection)	Female ISO 4400 with cable gland PG9 (IP65) Female plug ISO 4400 with cable gland PG13.5 (IP65) Female plug ISO 4400 with cable gland PG11 (IP65) Cable outlet incl. 2m cable, type PVC (IP67)
Mechanical connection	G1/4" DIN 3852, G1/4" EN 837, G1/4" NPT, G1/2" EN837
Material pressure port	1.4301 (304) for models 18.457G, 26.457G, 30.457G and 1.4571 (316Ti) for model 17.457G
Material housing	Stainless steel 1.4301(304)

Remarks:

The Ex-Proof parameters of the approved products originate from Ex- Certificate received from manufacturer, not approved/inspected by CCS.

The safety technical maximum values specified in the above-mentioned Ex-proof certificates are to be observed. This Type Approval Certification will be invalid if the approved products do not hold valid Ex-Certificate.

--The end--